

Fire Safety - Nominated Supervisor

NQS 2.2.2 Incident and emergency management

Name of the person conducting the checklist:	Date:		
Testing			
Smoke detectors are tested every month by pressing test button	OYes	ONo	ONA
Batteries in smoke detectors are replaced annually	OYes	ONo	ONA
All fire extinguishers are tested every 6 months	OYes	ONo	ONA
All fire blankets are tested every 6 months	OYes	ONo	ONA
Fire equipment is within expiry period ie current	OYes	ONo	ONA
Display			
Emergency plans is displayed in all rooms near exits	OYes	ONo	ONA
Evacuation procedures are displayed in all rooms near exits	OYes	ONo	ONA
Exit signs are displayed to identify exits	OYes	ONo	ONA
Emergency telephone numbers are displayed	OYes	ONo	ONA
Facilities			
Heating cooling units are inaccessible to children	OYes	ONo	ONA
Exit doors are always clear of obstructions/objects	OYes	ONo	ONA
Exit doors are unlocked when service is open	OYes	O No	ONA
There are no leaves or litter in the environment	OYes	ONo	ONA
Gutters are cleaned regularly	OYes	ONo	ONA
Lint is cleaned from the clothes dryer filter after every use	OYes	ONo	ONA
Insurance policies are up to date and cover relevant emergencies like fire	OYes	ONo	ONA
Consultation			
Relevant authorities are consulted where necessary eg for advice about location of assembly	O Yes	ONo	ONA
point, development of emergency procedures			
Rehearsals			
Evacuation procedures are rehearsed at least once every three months on different days and at different times	OYes	ONo	ONA
Everyone at the service participates in the rehearsal, including owners and managers	OYes	ONo	ONA
The emergency kit is fully stocked	O Yes	ONo	ONA
Daily Practices			
Children's art work/displays are kept away from heating/cooling units	O Yes	ONo	ONA
Curtains, tablecloths and bedding are kept away from heaters	O Yes	ONo	ONA
Power points are not overloaded	OYes	ONo	ONA
Appliances are switched off when not in use	OYes	ONo	ONA
Flammable chemicals are stored safely eg not near materials like art paper	O Yes	ONo	ONA
Cooking is never left unattended	O Yes	ONo	ONA
Practices in Emergency			
Attendance records (children and staff) are collected and checked to ensure everyone is accounted for	OYes	ONo	ONA
Specific person collects emergency kit	OYes	ONo	ONA
Specific person takes charged mobile phone with credit	OYes	ONo	ONA
Diary Notes			
There is a diary note to test smoke detector monthly	OYes	ONo	ONA
· · · · · · · · · · · · · · · · · · ·			

Copyright Centre Support Pty Ltd 2020 The service who has purchased this checklist product is the only service that can use this document. No part of this document can be copied, distributed, passed on or given to a friend outside the service who has not purchased the Centre Support Product. If this occurs Centre Support will take legal action against you personally and the person who has received it.

Page | 1



There is a diary note to change batteries in smoke detector annually	OYes	ONo	ONA
Actions required			